



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST
(Revised: 11/01/2023)

The attached list of self-contained meter sockets and enclosures has been approved for use in the service area served by the City of Tallahassee. Approval is based on the unit's compliance with the City of Tallahassee specifications, particularly U.L. listing, sealing requirements, bypass characteristics, and certain operational concerns. The City of Tallahassee makes no claims regarding nameplate ratings or load side attachments beyond the sealed portion of the meter socket. We recommend that all units be used as intended by the manufacturer. All additional data is supplied for informational purposes only.

NOTES:

- A. All commercial or three phase applications require a unit with an approved bypass device. (Configuration 3 or 4).
- B. All lugs/connectors (line and load side) are considered to be part of the meter enclosure. The customer/contractor is thereby responsible for furnishing these items.
- C. The "configuration" refers to the various meter connecting arrangements used to accommodate the utility meter. These configurations are described below:

SELF CONTAINED CONFIGURATIONS

DESCRIPTION & TYPICAL APPLICATION

1	Residential - 4 Terminal Socket, Single Phase, 3 Wire
2	Residential - 5 Terminal Socket, Network, 3 Wire
3	Residential/Commercial - 5 Terminal Socket (w/Bypass), Single Phase, 3 Wire
3a	Residential/Commercial - 5 Terminal Socket (w/Bypass), Network, 3 Wire
4	Commercial - 7 Terminal Socket (w/Bypass), Three Phase, 4 Wire



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Over/ Under	# Phase	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
ABB	125	RMS18x12LRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	125	RMS18x12HRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	125	RMS28x12LRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	125	RMS28x12HRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	125	RMS112x12LRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	125	RMS112x12HRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	125	RMS212x12LRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	125	RMS212x12HRLR** (x=2-6)			1	OH/UG	5	N 1,2
ABB	225	RMS18x22LRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS18x22HRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS28x22LRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS28x22HRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS112x22LRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS112x22HRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS212x22LRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS212x22HRLR** (x=2-5)			1	OH/UG	5	N 1,2
ABB	225	RMS112x22CHLBR** (x=1-4)			1	OH/UG	5	Y 3,3a
ABB	225	RMS212x22CHLBR** (x=1-4)			1	OH/UG	5	Y 3,3a
ABB	225	RMS312x22CHLBR** (x=1-4)			3	OH/UG	7	Y 4
ABB	400	RMS112x40CHLBRB** (x=1 or 2)			1	OH/UG	5	Y 3,3a
ABB	400	RMS212x40CHLBRB** (x=1 or 2)			1	OH/UG	5	Y 3,3a
ABB	400	RMS312140CHLBR**			3	OH/UG	7	Y 4
ABB	400	RMS312x40CHLBRB** (x=1 or 2)			3	OH/UG	7	Y 4
Brooks	200	601U43V3B41-B20A01			1	OH/UG	4	Y 3
Brooks	200	601U43V3B51-B20A01			3	OH/UG	5	Y 3a
Brooks	200	601U43V3B71-B20A01			3	OH/UG	7	Y 4
Brooks	400	601U44V3B41-B32A01			1	OH/UG	4	Y 3
Brooks	400	601U44V3B51-B32A01			1	OH/UG	5	Y 3a
Brooks	400	601U44V3B71-B32A01			3	OH/UG	7	Y 4
Durham	200	UAT-H4203x-FL (x=B or T)			1	OVER	4	Y 1 Al
Durham	200	UAT-H4213x-FL (x=C or U)			1	OH/UG	4	Y 1 Al
Durham	200	UAT-H5203x-FL			1	OVER	5	Y 3,3a,b Al
Durham	200	UAT-H5213x-FL (x=C or U)			1	OH/UG	5	Y 3,3a,b Al
Durham	200	UAT-H7203x-FL (x=B or T)			3	OVER	7	Y 4 Al
Durham	200	UAT-H7213x-FL (x=C or U)			3	OH/UG	7	Y 4 Al



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Durham	200	UAT-RS202B-FL			1	OVER	4 N	1 Al
Durham	200	UAT-RS212C-FL			1	OH/UG	4 N	1 Al
Durham	200	UAT-RS213A-FL			1	UNDER	4 N	1 Al
Durham	200	UAT-RS213C-FL			1	OH/UG	4 N	1 Al
Durham	200	UAT-4R2352UFL			1	OH/UG	4 N	1 Al
Durham	200	UAT-xR2392UUFL (x=5-6)			1	OH/UG	4 N	1 Al
Durham	200	UAT-xR2332U-FL (x=2-3)			1	OH/UG	4 N	1
Durham	200	UAT-RS223A-FL			1	UNDER	4 N	1 Al
Durham	200	UT-4R2352U-FL			1	OH/UG	4 N	1
Durham	200	UT92197CC-FL			1	OH/UG	4 N	1
Durham	200	UT-RS213C-FL			1	OH/UG	4 N	1
Durham	200	UT-H7213x-FL (x=C or U)			3	OH/UG	7 Y	1
Durham	200	UT-RS212C-FL			1	OH/UG	4 N	1
Durham	200	UT-RS202B-FL			1	OVER	4 N	1
Durham	200	UT-H4203x-FL (x=B or T)			1	OVER	4 Y	1
Durham	200	UT-H4213x-FL (x=C or U)			1	OH/UG	4 Y	1
Durham	200	UT-H5203x-FL (x=B or T)			1	OVER	5 Y	3,3a,b Al
Durham	200	UT-H5213x-FL (x=C or U)			1	OH/UG	5 Y	3,3a,b Al
Durham	200	UT-H7203x-FL (x=B or T)			3	OVER	7 Y	4
Durham	200	UT-RS213A-FL			1	UNDER	4 Y	1
Durham	200	UT-RS223A-FL			1	UNDER	4 N	1
Durham	200	UT-xR2332U-FL (x=2-3)			1	OH/UG	4 N	1
Durham	200	UT-xR2392UU-FL (x=5-6)			1	OH/UG	4 N	1
Durham	320	UAT-H5330U-FL			1	OH/UG	5 Y	3,3a,b Al
Durham	400	1011619			1	OH/UG	4 Y	1
Durham	400	1008836			1	OH/UG	4 Y	1
Durham	400	1008837			1	OH/UG	4 Y	1 Al
Durham	400	UAT-H5300T-FL			1	OVER	5 Y	3,3a,b Al
Durham	400	UAT-H7300T-FL			3	OVER	7 Y	4 Al
Durham	400	UAT-H7330U-FL			3	OH/UG	7 Y	4 Al
Durham	400	UT-H4300T-FL			1	OVER	4 Y	1
Durham	400	UT-H5300T-FL			1	OVER	5 Y	3,3a,b
Durham	400	UT-H5330U-FL			1	OH/UG	5 Y	3,3a,b
Durham	400	UT-H7300T-FL			3	OVER	7 Y	4
Durham	400	UT-H7336-8UFL			3	OH/UG	7 Y	4



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Over/Under Phase	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Durham	400	UT-H43068T-FL		1	OH/UG	4	Y 1
Durham	400	UT-H7330U-FL		3	OH/UG	7	Y 4
Eaton B-Line	100	ECCB10L25A3xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	Y 3a
Eaton B-Line	100	ECCB10L27A3xx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	100	ENCB10L25A3xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	N 1,2
Eaton B-Line	100	HEC10432Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	Y 3
Eaton B-Line	100	HEC10433Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	Y 3
Eaton B-Line	100	HEN10432Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	100	HEN10433Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	100	HEN10434Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	100	HEN10435Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	100	HEN10436Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	125	EC12L53xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	Y 3,3a,b
Eaton B-Line	125	EN12L41xx1F (xx=GR, AL, S4, S6)		1	OVER	4	N 1
Eaton B-Line	125	EN12L42xx1F (xx=GR, AL, S4, S6)		1	UNDER	4	N 1
Eaton B-Line	125	EN12L43xx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 1
Eaton B-Line	125	EN12L51xx1F (xx=GR, AL, S4, S6)		1	OVER	5	N 1,2
Eaton B-Line	125	EN12L52xx1F (xx=GR, AL, S4, S6)		1	UNDER	5	N 1,2
Eaton B-Line	125	EN12L53xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	N 1,2
Eaton B-Line	125	VENMP12432Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	125	VENMP12433Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	125	VENMP12434Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	125	VENMP12435Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	125	VENMP12436Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	150	ENCB15L25A3xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	N 1,2
Eaton B-Line	200	EL20L53xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	Y 3,3a,b
Eaton B-Line	200	EL20L73xx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	200	ELCB20L25A3xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	Y 3,3a
Eaton B-Line	200	ELCB20L27A3xx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	200	EN20L41xx1F (xx=GR, AL, S4, S6)		1	OVER	4	N 1
Eaton B-Line	200	EN20L42xx1F (xx=GR, AL, S4, S6)		1	UNDER	4	N 1
Eaton B-Line	200	EN20L43xx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 1
Eaton B-Line	200	EN20L51xx1F (xx=GR, AL, S4, S6)		1	OVER	5	N 1,2
Eaton B-Line	200	EN20L52xx1F (xx=GR, AL, S4, S6)		1	UNDER	5	N 1,2
Eaton B-Line	200	EN20L53xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	N 1,2



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Over/Under Phase	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Eaton B-Line	200	ENCB20L25A3xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	N 1,2
Eaton B-Line	200	HEL20432Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	Y 3
Eaton B-Line	200	HEL20433Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	Y 3
Eaton B-Line	200	HEL20434Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	Y 3
Eaton B-Line	200	HEL20435Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	Y 3
Eaton B-Line	200	HEL20436Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	Y 3
Eaton B-Line	200	HEL20732Cxx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	200	HEL20733Cxx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	200	HEL20734Cxx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	200	HEL20735Cxx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	200	HEL20736Cxx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	200	VENMP20432Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	200	VENMP20433Lxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	200	VENMP20434Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	200	VENMP20435Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	200	VENMP20436Cxx1F (xx=GR, AL, S4, S6)		1	OH/UG	4	N 3
Eaton B-Line	400	EL32T53xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	Y 3,3a
Eaton B-Line	400	EL32T56xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	Y 3,3a
Eaton B-Line	400	EL32T75xx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	400	EL32T76xx1F (xx=GR, AL, S4, S6)		3	OH/UG	7	Y 4
Eaton B-Line	400	ELCB32C25A5xx1F (xx=GR, AL, S4, S6)		1	OH/UG	5	Y 3,3a
Eaton-Cutler Hammer	100	MB1224B100BTS		1	OH/UG	4	N 1
Eaton-Cutler Hammer	100	UTZ-xR1121C-FLCH (x=2-5)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	100	UATZ-xR1121CFLCH (x=2-5)		1	OH/UG	4	N 1 AL
Eaton-Cutler Hammer	125	1MMx12RRLP or RRLCP (x=3-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	1MMx12RRL, RRLC (x=3-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	1MPx124RRLP or RRLCP (x=3-4)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	1MPx124RRL, RRLC (x=3-4)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	1MPx126RRLP or RRLCP (x=5-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	1MPx126RRL, RRLC (x=5-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	3MMx12R12RRLP (x=2-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	3MMx12R12RL (x=2-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	3MMx12RRLCP (x=2-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	3MMx12RRLP (x=2-6)		1	OH/UG	4	N 1
Eaton-Cutler Hammer	125	CHR (POWER OUTLET PANEL)		1	OH/UG	4	N 1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Eaton-Cutler Hammer	125	MBT48B125BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	125	UATZ-RS101C-FLCH			1	OH/UG	4 N	1 Al
Eaton-Cutler Hammer	125	UT-RS101xE (x=B,C)			1	OH/UG	4 N	1
Eaton-Cutler Hammer	125	UTZ-RS101C-FLCH			1	OH/UG	4 N	1
Eaton-Cutler Hammer	150	MB816B150BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	150	MBB150BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	150	MBT48B150BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	1MMx20RRLP or RRLCP (x=3-4)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	1MMx20RRL, RRLC (x=3-5)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	1MP2204RRLP or RRLCP			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	1MP2204RRL, RRLC			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	1MPx206RRLP or RRLCP (x=3-6)			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	1MPx206RRL, RRLC (x=3-6)			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	3MMx20R12RRLP (x=2-5)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	3MMx20R12RL (x=2-5)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	3MMx20RRLCP (x=2-5)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	3MMx20RRLC (x=2-5)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	3MMx20RRLP (x=2-5)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	3MMx20RRL (x=2-5)			1	OH/UG	4 N	3
Eaton-Cutler Hammer	200	CMB1212B200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	CMB1212L200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	CMB1212P200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	CMB2424B200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	CMB2436B200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MB1212L200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MB1212L200BTSA			1	OH/UG	4 N	1 Al
Eaton-Cutler Hammer	200	MB2040B200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MB2040P200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MB816B200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MB816P200BTS or BTSCU			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MBB200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MBP200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MBT48B200BTS			1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UAT-4R2352UFLCH			1	OH/UG	4 N	1 Al
Eaton-Cutler Hammer	200	UAT-H4203x-FLCH (x=B or T)			1	OVER	4 Y	1 Al



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Over/Under Phase	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Eaton-Cutler Hammer	200	UAT-H5203x-FLCH (x=B or T)		1	OVER	5 Y	3,3a,b Al
Eaton-Cutler Hammer	200	UAT-H7203x-FLCH (x=B or T)		3	OVER	7 Y	4 Al
Eaton-Cutler Hammer	200	UAT-RS202B-FLCH		1	OVER	4 N	1 Al
Eaton-Cutler Hammer	200	UAT-RS212C-FLCH		1	OH/UG	4 N	1 Al
Eaton-Cutler Hammer	200	UAT-RS213A-FLCH		1	UNDER	4 N	1 Al
Eaton-Cutler Hammer	200	UAT-RS213C-FLCH		1	OH/UG	4 N	1 Al
Eaton-Cutler Hammer	200	UAT-RS223A-FLCH		1	UNDER	4 N	1 Al
Eaton-Cutler Hammer	200	UAT-xR2332U-FLCH (x=2-3)		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UATxR2392UUFLCH (x=5-6)		1	OH/UG	4 N	1 Al
Eaton-Cutler Hammer	200	UAT-y4213x-FLCH (y=E or H, where x=C or U)		1	OH/UG	4 Y	1 Al
Eaton-Cutler Hammer	200	UAT-y5213x-FLCH (y=E or H, where x=C or U)		1	OH/UG	5 Y	3,3a,b Al
Eaton-Cutler Hammer	200	UAT-y7213x-FLCH (y=E or H, where x=C or U)		3	OH/UG	7 Y	4 Al
Eaton-Cutler Hammer	200	UT-4R2352U-FLCH		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UT92197CC-FL-CH		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UT-RS202B-FLCH		1	OVER	4 N	1
Eaton-Cutler Hammer	200	UT-RS213A-FLCH		1	UNDER	4 N	1
Eaton-Cutler Hammer	200	UT-RS213xE (x=A, B, C)		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UT-RS213C-FLCH		1	OH/UG	4/5 N	1,2
Eaton-Cutler Hammer	200	UT-RS223A-FLCH		1	UNDER	4 N	1
Eaton-Cutler Hammer	200	UT-xR2332U-FLCH (x=2-3)		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UT-xR2392UU-FLCH (x=5-6)		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UT-y4203x-FLCH (y=E or H, where x=B or T)		1	OVER	4 Y	1
Eaton-Cutler Hammer	200	UT-y4213x-FLCH (y=E or H, where x=C or U)		1	OH/UG	4 Y	1
Eaton-Cutler Hammer	200	UT-y5203x-FLCH (y=E or H, where x=B or T)		1	OVER	5 Y	3,3a,b
Eaton-Cutler Hammer	200	UT-y5213x-FLCH (y=E or H, where x=C or U)		1	OH/UG	5 Y	3,3a,b
Eaton-Cutler Hammer	200	UT-y7203x-FLCH (y=E or H, where x=B or T)		3	OVER	7 Y	4
Eaton-Cutler Hammer	200	MB48B200BTSG		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	MB2040PV200BTS		1	OH/UG	4 N	1
Eaton-Cutler Hammer	200	UT-y7213x-FLCH (where y=E or H, x=C or U)		3	OH/UG	7 Y	4
Eaton-Cutler Hammer	225	35MMx20R12 or R12C (x=1-4)		1	OH/UG	5 Y	3,3a
Eaton-Cutler Hammer	225	37MMx20R12 or R12C (x=1-4)		3	OH/UG	7 Y	4
Eaton-Cutler Hammer	400	1008836CH		1	OH/UG	4 Y	1
Eaton-Cutler Hammer	400	1008837CH		1	OH/UG	4 Y	1 Al
Eaton-Cutler Hammer	400	1011619CH		1	OH/UG	4 Y	1
Eaton-Cutler Hammer	400	35MM140R1240		1	UNDER	5 Y	3



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Eaton-Cutler Hammer	400	35MM240R1240			1	UNDER	5 Y	3
Eaton-Cutler Hammer	400	37MM140R1240			3	UNDER	7 Y	4
Eaton-Cutler Hammer	400	37MM240R1240			3	UNDER	7 Y	4
Eaton-Cutler Hammer	400	CG1212P400BSL			1	UNDER	4 Y	3
Eaton-Cutler Hammer	400	CG404242SHL			1	UNDER	4 Y	3
Eaton-Cutler Hammer	400	CG40SHL			1	UNDER	4 Y	3
Eaton-Cutler Hammer	400	HP404040SHL			1	UNDER	4 Y	3
Eaton-Cutler Hammer	400	HP40SHL			1	UNDER	4 Y	3
Eaton-Cutler Hammer	400	HP816Px00BSL (x= 3 or 4)			1	UNDER	4 Y	3
Eaton-Cutler Hammer	400	HPCx046SHLG (x= 3 or 4)			1	OH/UG	4 y	3
Eaton-Cutler Hammer	400	HPCx0SHL (x= 3 or 4)			1	OH/UG	4 y	3
Eaton-Cutler Hammer	400	UAT-H4300T-FLCH			1	OVER	4 Y	1 Al
Eaton-Cutler Hammer	400	UAT-H5300T-FLCH			1	OVER	5 Y	3,3a,b Al
Eaton-Cutler Hammer	400	UAT-H5330U-FLCH			1	OH/UG	5 Y	3,3a,b Al
Eaton-Cutler Hammer	400	UAT-H7300T-FLCH			3	OVER	7 Y	4 Al
Eaton-Cutler Hammer	400	UAT-H7330U-FLCH			3	OH/UG	7 Y	4 Al
Eaton-Cutler Hammer	400	UT-H4300T-FLCH			1	OVER	4 Y	1
Eaton-Cutler Hammer	400	UT-H43068T-FLCH			1	OH/UG	4 Y	1
Eaton-Cutler Hammer	400	UT-H5300T-FLCH			1	OVER	5 Y	3,3a,b
Eaton-Cutler Hammer	400	UT-H5330U-FLCH			1	OH/UG	5 Y	3,3a,b
Eaton-Cutler Hammer	400	UT-H7300T-FLCH			3	OVER	7 Y	4
Eaton-Cutler Hammer	400	UT-H7330U-FLCH			3	OH/UG	7 Y	4
Eaton-Cutler Hammer	400	UTH73368UFLCH			3	OH/UG	7 Y	4
Eaton-Cutler Hammer	600	CH9526K7 (Requires Ridged Lugs) FPL ONLY			3	OH/UG	7 Y	5
Eaton-Cutler Hammer	600	CH9527K7 (Requires Ridged Lugs) FPL ONLY			3	OH/UG	7 Y	5 Al
Elec.Prod.	100	RVP-xxxx-FPL			1	UNDER	4 N	1
Elec.Prod.	200	MHP-xxxx-FPL			1	UNDER	4 N	1
Emerson	125	MESBGFXLW11FBZ1			1	UNDER	5 Y	3a
Emerson	125	MESBGFXLW11FBZ1P			1	UNDER	5 Y	3a
Emerson	125	MESBGFXLW11KBZ1			1	UNDER	5 Y	3a
Emerson	125	MESBGFXLW11KBZ1P			1	UNDER	5 Y	3a
Emerson	200	MESBAATLW11FBZ1			1	UNDER	5 Y	3a
Emerson	200	MESBAATLW11FBZ1P			1	UNDER	5 Y	3a
Emerson	200	MESBAATLW11KBZ1			1	UNDER	5 Y	3a
Emerson	200	MESBAATLW11KBZ1P			1	UNDER	5 Y	3a



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Over/Under Phase	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Generac	200	RXUW200A3 (w/ integrated transfer switch for standby)		1	OH/UG	4/5	N 1
Generac	150	RXUW150A3 (w/integrated transfer swtich for standby)		1	OH/UG	4/5	N 1
Generac	200	RBU200A3 (transfer switch not included)		1	OH/UG	4/5	N 1
Generac	150	RBU150A3 (transfer switch not included)		1	OH/UG	4/5	N 1
General Electric	(2)	TSDR830USCU		1	UNDER	4/5	Y 1,2
General Electric	100	UATZ-xR1121CFLGE (x=2-5)		1	OH/UG	4	N 1 Al
General Electric	100	TM10RMCFMG		1	OH/UG	4	N 1
General Electric	100	UTZ-6R1131CFLGE		1	OH/UG	4	N 1
General Electric	100	UTZ-xR1121CFLGE (x=2-5)		1	OH/UG	4/5	N 1,2
General Electric	125	TM12RMCFMG		1	OH/UG	4	N 1
General Electric	125	TMMR2212RF		1	OH/UG	4/5	N 1,2
General Electric	125	TMMR4x12RF (x=3-4)		1	UNDER	4/5	N 1,2
General Electric	125	TMMR6x12RF (x=5-6)		1	UNDER	4/5	N 1,2
General Electric	125	TMPR12520RBUS		1	OH/UG	5	N 2
General Electric	125	TMPR12x12RF (x=2-6)		1	OH/UG	5	N 2
General Electric	125	TMPR8520RBUS		1	OH/UG	5	N 2
General Electric	125	TMPR8x12RF (x=2-6)		1	OH/UG	4	N 1,2
General Electric	125	UATZ-RS101CFLGE		1	OH/UG	4	N 1 Al
General Electric	125	UTZ-RS101C-FLGE		1	OH/UG	4	N 1
General Electric	150	TM15RMCFMG		1	OH/UG	4	N 1
General Electric	150	TSMR415CSFLFMG		1	OH/UG	5	N 2
General Electric	150	TSMR815CSFLFMG		1	OH/UG	5	N 2
General Electric	200	TM20RMCFMG		1	OH/UG	4	N 1
General Electric	200	TMMR4220RF		1	UNDER	5	N 2
General Electric	200	TMMR6x20RF (x=3-6)		1	UNDER	5	N 2
General Electric	200	TMPR12x20RF (x=4-5)		1	OH/UG	5	N 2
General Electric	200	TMPR8x20RF (x=2-5)		1	OH/UG	5	N 2
General Electric	200	TSLR1220FSAL		1	OH/UG	4/5	N 1, 2
General Electric	200	TSMR2020CSCUFMG		1	OH/UG	4/5	N 1,2
General Electric	200	UT-RS202B-FLGE		1	OVER	4	N 1
General Electric	200	TSMRx20CSFLFMG (x = 4, 8)		1	OH/UG	4/5	N 1,2
General Electric	200	UAT-H4203x-FLGE (x=B or T)		1	OVER	4	Y 1 Al
General Electric	200	UAT-H4213x-FLGE (x=C or U)		1	OH/UG	4	Y 1 Al
General Electric	200	UAT-H5203x-FLGE (x=B or T)		1	OVER	5	Y 3,3a,b Al
General Electric	200	UAT-H5213x-FLGE (x=C or U)		1	OH/UG	5	Y 3,3a,b Al



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
General Electric	200	UAT-H7203x-FLGE (x=B or T)			3	OVER	7 Y	4 Al
General Electric	200	UAT-xR2392UUFLGE (x=5-6)			1	OH/UG	4 N	1 Al
General Electric	200	UAT-H7213x-FLGE (x=C or U)			1	OH/UG	7 Y	4 Al
General Electric	200	UAT-4R2352UFLGE			1	OH/UG	4 N	1 Al
General Electric	200	UAT-xR2332U-FLGE (x=2-3)			1	OH/UG	4 N	1
General Electric	200	UAT-RS202B-FLGE			1	OVER	4 N	1 Al
General Electric	200	UAT-RS212C-FLGE			1	OH/UG	4 N	1 Al
General Electric	200	UAT-RS213A-FLGE			1	UNDER	4 N	1 Al
General Electric	200	UAT-RS213C-FLGE			1	OH/UG	4 N	1 Al
General Electric	200	UAT-RS223A-FLGE			1	UNDER	4 N	1 Al
General Electric	200	UT-4R2352U-FLGE			1	OH/UG	4 N	1
General Electric	200	UT92197CC-FL-GE			1	OH/UG	4 N	1
General Electric	200	UT-H7213x-FL-GE (x=C or U)			3	OH/UG	7 Y	1
General Electric	200	UT-RS212C-FL-GE			1	OH/UG	4 N	1
General Electric	200	UT-H4203x-FL-GE (x=B or T)			1	OVER	4 Y	1
General Electric	200	UT-H4213x-FL-GE (x=C or U)			1	OH/UG	4 Y	1
General Electric	200	UT-H5203x-FL-GE (x=B or T)			1	OVER	5 Y	3,3a,b
General Electric	200	UT-H5213x-FL-GE (x=C or U)			1	OH/UG	5 Y	3,3a,b
General Electric	200	UT-H7203x-FL-GE (x=B or T)			1	OVER	7 Y	4
General Electric	200	UT-RS213A-FL-GE			1	UNDER	4 N	1
General Electric	200	UT-RS213C-FL-GE			1	OH/UG	4 N	1
General Electric	200	UT-RS223A-FL-GE			1	UNDER	4 N	1
General Electric	200	UT-xR2332U-FLGE (x=2-3)			1	OH/UG	4 N	1
General Electric	200	UT-xR2392UUFLGE (x=5-6)			1	OH/UG	4 N	1
General Electric	225	TMPR12x22R (x=1-4)			1	OH/UG	5 Y	3,3a
General Electric	225	TMPR312x22RF (x=1-4)			3	OH/UG	7 Y	4
General Electric	400	1011619-GE			1	OH/UG	4 Y	1
General Electric	400	1008836-GE			1	OH/UG	4 Y	1
General Electric	400	1008837-GE			1	OH/UG	4 Y	1 Al
General Electric	400	TMPR12x40RB (x=1-2)			1	OH/UG	5 N	3,3a
General Electric	400	TMPR312x40RB (x=1-2)			3	OH/UG	7 Y	4
General Electric	400	TSDR840UFCU			1	UNDER	4/5 Y	1,2
General Electric	400	UAT-H4300T-FLGE			1	OVER	4 Y	1 Al
General Electric	400	UAT-H5300T-FLGE			1	OVER	5 Y	3,3a,b Al
General Electric	400	UAT-H5330U-FLGE			1	OH/UG	5 Y	3,3a Al



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
General Electric	400	UAT-H7300T-FLGE			3	OVER	7 Y	4 AL
General Electric	400	UAT-H7330U-FLGE			3	OH/UG	7 Y	4 AL
General Electric	400	UT-H4300T-FL-GE			1	OVER	4 Y	1
General Electric	400	UT-H5300T-FL-GE			1	OVER	5 Y	3,3a,b
General Electric	400	UT-H5330U-FL-GE			1	OH/UG	5 Y	3,3a,b
General Electric	400	UT-H43068T-FLGE			1	OH/UG	4 Y	1
General Electric	400	UT-H7300T-FL-GE			3	OVER	7 Y	4
General Electric	400	TSDR840CFCUGP (2 - 200amp breakers)			1	OH/UG	4/5 Y	1,2
General Electric	300	TSDR830CFCUGP (2 - 150amp breakers)			1	OH/UG	4/5 Y	1,2
General Electric	400	UT-H7336-8UFLGE			3	OH/UG	7 Y	4
General Electric	400	UT-H7330U-FL-GE			3	OH/UG	7 Y	4
Jamestown Advanced	125	PSURF-RL-YYY-ZZ (y=5,3, or 2) (z=NO, SL, or CL)**			1	OH	4 N	1
Jamestown Advanced	125	PPEDE-RL-YYY-ZZ (y=5,3, or 2) (z=NO, SL, or CL)**			1	UG	4 N	1
Jamestown Advanced	125	PPADM-RL-YYY-ZZ (y=5,3, or 2) (z=NO, SL, or CL)**			1	UG	4 N	1
Leviton	150	LP815-TMC			1	OH/UG	4 N	1
Leviton	150	LS815-BTD			1	OH/UG	4 N	1
Leviton	150	LP815-MC			1	OH/UG	4 N	1
Leviton	150	LP815-5MC			1	OH/UG	5 Y	2
Leviton	150	LS815-B5D			1	OH/UG	5 Y	2
Leviton	150	LP815-LMC			1	OH/UG	4 Y	1
Leviton	150	LS815-BLD			1	OH/UG	4 Y	1
Leviton	150	LS130-250-S5D			1	OH/UG	5 Y	2,3a
Leviton	150	LS130-2L0-SLD			1	OH/UG	4 Y	1,3
Leviton	200	LS140-250-S5D			1	OH/UG	5 Y	2,3a
Leviton	200	LS140-2L0-SLD			1	OH/UG	4 Y	1,3
Leviton	200	LP820-TMC			1	OH/UG	4 N	1
Leviton	200	LS820-BTD			1	OH/UG	4 N	1
Leviton	200	LP820-5MC			1	OH/UG	5 Y	2
Leviton	200	LS820-B5D			1	OH/UG	5 Y	2
Leviton	200	LP820-LMC			1	OH/UG	4 Y	1
Leviton	200	LS820-BLD			1	OH/UG	4 Y	1
Leviton	200	LP820-MC			1	OH/UG	4 N	1
Midwest	100	R175MCB6010FMG**			1	Un-Ped	4 N	1
Midwest	100	R175MCP6010FMG**			1	Un-Ped	4 N	1
Midwest	100	R111CB2010**			1	OH/UG	4 N	1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Midwest	100	R138CB2033**			1	OH/UG	4 N	1
Midwest	100	R176CB2033**			1	OH/UG	4 N	1
Midwest	100	R111MBC010U**			1	UNDER	4 N	1
Midwest	100	R111MBC010**			1	OVER	4 N	1
Midwest	100	R138MBC033U**			1	UNDER	4 N	1
Midwest	100	R138MBC033**			1	OVER	4 N	1
Midwest	100	R075CB6010FMG			1	Un-Ped	4 N	1
Midwest	100	R075CP6010FMG			1	Un-Ped	4 N	1
Midwest	100	R101CB2FMG			1	OH/UG	4 N	1
Midwest	100	R101CP6FMG			1	Un-Ped	4 N	1
Midwest	100	R102EN			1	OVER	4 N	1
Midwest	100	RH75CB3FMG			1	Un-Ped	4 N	1
Midwest	100	RH75CP3FMG			1	Un-Ped	4 N	1
Midwest	100	UTZ6R1131CFLMEP			1	OH/UG	4 N	1
Midwest	100	UATZ-xR1121CFLMEP (x=2-5)			1	OH/UG	4 N	1 AI
Midwest	100	UTZxR1121CFLMEP (x=2-5)			1	OH/UG	4 N	1
Midwest	125	UATZRS101CFLMEP			1	OH/UG	4 N	1 AI
Midwest	125	UTZ-RS101CFLMEP			1	OH/UG	4 N	1
Midwest	150	R158CR2TLFMG			1	OH/UG	4 N	1
Midwest	150	RS43308C (2x 150MB)			1	OH/UG	4 Y	3
Midwest	200	R208CP6HPFMG			1	Un-Ped	4 N	1
Midwest	200	R208CR2TLFMG			1	OH/UG	4 N	1
Midwest	200	R256EB118FMG			1	OH/UG	4 N	1 AI
Midwest	200	R256EB1FMG			1	OH/UG	4 N	1
Midwest	200	R256EB1NFMG			1	OH/UG	4 N	1
Midwest	200	R281C1B6HFMG			1	Un-Ped	4 N	1
Midwest	200	R281C1P6HFMG			1	Un-Ped	4 N	1
Midwest	200	R281CB1FMG			1	OH/UG	4 N	1
Midwest	400	RS45500C (2 X 200MB)			1	UNDER	4 Y	3
Midwest	400	RS45508C (2 X 200MB)			1	UNDER	4 Y	3
Midwest	200	UT-RS212C-FL-MEP			1	OH/UG	4 N	1
Midwest	200	UAT-xR2332U-FLMEP (x=2-3)			1	OH/UG	4 N	1
Midwest	200	UT-RS202B-FL-MEP			1	OVER	4 N	1
Midwest	200	UAT-4R2352UFLMEP			1	OH/UG	4 N	1 AI
Midwest	200	UAT-H4203xFLMEP (x=B or T)			1	OVER	4 Y	1 AI



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Midwest	200	UAT-H4213xFLMEP (x=C or U)			1	OH/UG	4 Y	1 Al
Midwest	200	UAT-H5203xFLMEP (x=B or T)			1	OVER	5 Y	3,3a,b Al
Midwest	200	UAT-H5213xFLMEP (x=C or U)			1	OH/UG	5 Y	3,3a,b Al
Midwest	200	UAT-H7203x-FLMEP (x=B or T)			3	OVER	7 Y	4 Al
Midwest	200	UAT-xR2392UUFLEMEP (x=5-6)			1	OH/UG	4 N	1 Al
Midwest	200	UAT-H7213xFLMEP (x=C or U)			3	OH/UG	7 Y	4 Al
Midwest	200	UAT-RS202BFLMEP			1	OVER	4 N	1 Al
Midwest	200	UAT-RS212CFLMEP			1	OH/UG	4 N	1 Al
Midwest	200	UAT-RS213AFLMEP			1	UNDER	4 N	1 Al
Midwest	200	UAT-RS213CFLMEP			1	OH/UG	4 N	1 Al
Midwest	200	UAT-RS223AFLMEP			1	UNDER	4 N	1 Al
Midwest	200	UT-4R2352UFLMEP			1	OH/UG	4 N	1
Midwest	200	UT92197CC-FLMEP			1	OH/UG	4 N	1
Midwest	200	UT-H4203x-FLMEP (x=B or T)			1	OVER	4 Y	1
Midwest	200	UT-H4213x-FLMEP (x=C or U)			1	OH/UG	4 Y	1
Midwest	200	UT-H5203x-FLMEP (x=B or T)			1	OVER	5 Y	3,3a,b
Midwest	200	UT-H5213x-FLMEP (x=C or U)			1	OH/UG	5 Y	3,3a,b
Midwest	200	UT-H7203x-FLMEP (x=B or T)			3	OVER	7 Y	4
Midwest	200	UT-RS213A-FLMEP			1	UNDER	4 N	1
Midwest	200	UT-RS213C-FLMEP			1	OH/UG	4 N	1
Midwest	200	UT-RS223A-FLMEP			1	UNDER	4 N	1
Midwest	200	UT-H7213x-FLMEP (x=C or U)			3	OH/UG	7 Y	1
Midwest	200	UT-xR2332UFLMEP (x=2-3)			1	OH/UG	4 N	1
Midwest	400	UT-H43068T-FLMEP			1	OH/UG	4 Y	1
Midwest	200	UTxR2392UUFLEMEP (x = 5-6)			1	OH/UG	4 N	1
Midwest	400	1011619-MEP			1	OH/UG	4 Y	1
Midwest	400	1008836-MEP			1	OH/UG	4 Y	1
Midwest	400	1008837-MEP			1	OH/UG	4 Y	1 Al
Midwest	400	RS45524CFMG			1	UNDER	4/5 Y	1,2
Midwest	400	UAT-H4300TFLMEP			1	OVER	4 Y	1 Al
Midwest	400	UAT-H5300TFLMEP			1	OVER	5 Y	3,3a,b Al
Midwest	400	UAT-H5330UFLMEP			1	OH/UG	5 Y	3,3a,b Al
Midwest	400	UAT-H7300TFLMEP			3	OVER	7 Y	4 Al
Midwest	400	UAT-H7330UFLMEP			3	OH/UG	7 Y	4 Al
Midwest	400	UT-H4300T-FLMEP			1	OVER	4 Y	1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Midwest	400	UT-H5300T-FLMEP			1	OVER	5 Y	3,3a,b
Midwest	400	UT-H5330UFLMEP			1	OH/UG	5 Y	3,3a,b
Midwest	400	UT-H7300TFLMEP			3	OVER	7 Y	4
Midwest	400	UT-H7336-8UFLMEP			3	OH/UG	7 Y	4
Midwest	400	UT-H7330UFLMEP			3	OH/UG	7 Y	4
Milbank	60	USS6542-RL-5T9HSP (Stainless)			1	OVER	4/5 Y	1,2,3,3a
Milbank	60	USSP6542-RL-5T9HSP (Stainless Painted)			1	OVER	4/5 Y	1,2,3,3a
Milbank	60	UAP6542-RL-5T9HSP (Painted Aluminum)			1	OVER	4/5 Y	1,2,3,3a
Milbank	60	UA6542-RL-5T9HSP (Aluminum)			1	OVER	4/5 Y	1,2,3,3a
Milbank	60	U6542-RL-5T9-HSP			1	OVER	4/5 Y	1,2,3,3a
Milbank		UAP5844-RL-Y-HSP (Y=100, 150, 200 AMPS)			1	OH/UG	4 N	1
Milbank		U5844-RL-Y-HSP (Y=100, 150, 200 AMPS)			1	OH/UG	4 N	1
Milbank	100	U4908-O-100MB-11GR-HSP**			1	OH/UG	4 N	1
Milbank	100	U5101-XL-100MB-11GR-HSP**			1	OH/UG	4 N	1
Milbank	100	U349y-XL-HSP (y=2-6)			1	OH/UG	4/5 N	1,2
Milbank	100	U513y-O-100P-FMG (y=6-9)			1	Un-Ped	4/5 N	1,2
Milbank	100	U513y-O-100S-10GR-FMG (y=6-9)			1	Un-Ped	4/5 N	1,2
Milbank	100	U513y-O-100S-FMG (y=6-9)			1	Un-Ped	4/5 N	1,2
Milbank	100	U5842-RL-100-HSP			1	OVER	4 N	1
Milbank	100	U6266-XTL-100-HSP			1	OH/UG	4/5 N	1,2
Milbank	100	UAP349y-XL-HSP (y=2-6)			1	OH/UG	4/5 N	1,2 Al
Milbank	100	U6396-O-100-10GR-HSP			1	UNDER	4 Y	3
Milbank	125	U285y-X-HSP (y=2-6)			1	OH/UG	4/5 N	1,2
Milbank	125	U3505-XL-HSP			1	OH/UG	5 Y	3,3a
Milbank	125	U3505-XL-TG-HSP			1	OH/UG	5 Y	3,3a
Milbank	125	U3506-XL-TG-HSP			3	OH/UG	7 Y	4
Milbank	125	U4908-O-11GR-HSP			1	UNDER	4 N	1
Milbank	125	U5101-XL-11GR-HSP			1	OVER	4 N	1
Milbank	125	U513y-O-125P-FMG (y=6-9)			1	Un-Ped	4/5 N	1,2
Milbank	125	U513y-O-125S-FMG (y=6-9)			1	Un-Ped	4/5 N	1,2
Milbank	125	U8435-XL-TG-HSP			1	OVER	4/5 N	1,2
Milbank	125	UAP3505-XL-TG-HSP			1	OH/UG	5 Y	3,3a Al
Milbank	125	UAP3506-XL-TG-HSP			3	OH/UG	7 Y	4 Al
Milbank	125	UAP8435-XL-TG-HSP			1	OH/UG	4/5 N	1,2 Al
Milbank	125	U590(y)-X-HSP (y= #of positions, 2,3,4,5,6)			1	Mtr Ctr	4/5 N	1,2



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Over/Under Phase	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Milbank	150	U123y-X-HSP (y=2-6)		1	OH/UG	4/5 N	1,2
Milbank	150	U513y-O-150P-FMG (y=6-9)		1	Un-Ped	4/5 N	1,2
Milbank	150	U513y-O-150S-10GR-FMG (y=6-9)		1	Un-Ped	4/5 N	1,2
Milbank	150	U513y-O-150S-FMG (y=6-9)		1	Un-Ped	4/5 N	1,2
Milbank	150	U5842-RL-150-HSP		1	OVER	4 N	1
Milbank	150	U6266-XTL-150-HSP		1	OH/UG	4/5 N	1,2
Milbank	200	CP3B5####x##### (x= D,P,R,S)(#=Cust. Option)		1	Un-Ped	4/5 Y	3,3a
Milbank	200	CP3B5####x##### (x= D,P,R,S)(#=Cust. Option)		3	Un-Ped	5/7 Y	3b,4
Milbank	200	CP3A5xxxxM (x= customer options)		1	Un-Ped	4/5 Y	3,3a
Milbank	200	CP3A5xxxxK (x = customer options)		3	Un-Ped	5/7 Y	3b,4
Milbank	200	CP2BXXXXN x= multiple customer side configurations		1	OH/UG	4 Y	1,3
Milbank	200	U125Y-X-HSP (y=2-6)		1	OH/UG	4/5 N	1,2
Milbank	200	U1980-O-HSP		1	UNDER	4/5 N	1,2
Milbank	200	U273y-XT-HSP (y=2-6)		3	OH/UG	7 Y	4
Milbank	200	U286y-X-HSP (y=2-6)		1	OH/UG	4/5 N	1,2
Milbank	200	U287y-XT-HSP (y=2-6)		1	OH/UG	5 Y	3,3a
Milbank	200	U3296-X-HSP		1	OH/UG	5 Y	3,3a,3b
Milbank	200	U3306-X-HSP		3	OH/UG	7 Y	4
Milbank	200	U3850-XL-TG-HSP-PL		1	OH/UG	4/5 N	1,2
Milbank	200	U5136-O-yyy-FMG (yyy=41,55,75,332,552)		1	Un-Ped	4/5 N	1,2
Milbank	200	U5137-O-yyy-FMG (yyy=41,55,75,332,552)		1	Un-Ped	4/5 N	1,2
Milbank	200	U513y-O-200P-FMG (y=6-9)		1	Un-Ped	4/5 N	1,2
Milbank	200	U513y-O-200S-10GR-FMG (y=6-9)		1	Un-Ped	4/5 N	1,2
Milbank	200	U513y-O-200S-FMG (y=6-9)		1	Un-Ped	4/5 N	1,2
Milbank	200	U513y-O-FMG (y=6-9)		1	Un-Ped	4/5 N	1,2
Milbank	200	U5842-RL-200-HSP		1	OVER	4 N	1
Milbank	200	U6266-XTL-200-HSP		1	OH/UG	4/5 N	1,2
Milbank	200	U6396-O-200-HSP-CCDOT (30amp cust. breaker)		1	Un-Ped	4 Y	3
Milbank	200	U6435-O-200-HSP-CCDOT (30amp cust. breaker)		1	Un-Ped	4 Y	3
Milbank	200	U6396-O-200-HSP-NCDOT (50amp cust. breaker)		1	Un-Ped	4 Y	3
Milbank	200	U6435-O-200-HSP-NCDOT (50amp cust. breaker)		1	Un-Ped	4 Y	3
Milbank	200	U7021-RL-TG-HSP		1	OVER	4/5 N	1,2
Milbank	200	U7040-O-TG-HSP		1	UNDER	4 N	1,2
Milbank	200	U7040-XL-TG-5T-HSP		1	OH/UG	5 N	1,2
Milbank	200	U7040-XL-TG-HSP		1	OH/UG	4/5 N	1,2



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Milbank	200	U9550-RRL-QG-HSP			1	OVER	5 Y	3,3a,b
Milbank	200	U9551-X-QG-HSP			1	OH/UG	5 Y	3,3a,b
Milbank	200	U9700-RRL-QG-HSP			3	OVER	7 Y	4
Milbank	200	U9701-X-QG-HSP			3	OH/UG	7 Y	4
Milbank	200	U9801-X-QG-HSP			1	OH/UG	4 Y	1,2
Milbank	200	UAP125y-X-HSP (y=2-6)			1	OH/UG	4/5 Y	1,2 Al
Milbank	200	UAP1980-O-HSP			1	UNDER	4/5 N	1,2 Al
Milbank	200	UAP3296-X-HSP			1	OH/UG	5 Y	3,3a,b Al
Milbank	200	UAP3306-X-HSP			3	OH/UG	7 Y	4 Al
Milbank	200	UAP5024-XL-FMG			1	OH/UG	4 N	1 Al
Milbank	200	UAP7021-RL-TG-HSP			1	OVER	4/5 N	1,2 Al
Milbank	200	UAP7040-O-TG-HSP			1	UNDER	4/5 N	1,2 Al
Milbank	200	UAP7040-XL-TG-HSP			1	OH/UG	4/5 N	1,2 Al
Milbank	200	UAP9551-X-QG-HSP			1	OH/UG	5 Y	3,3a,b Al
Milbank	200	UAP9700-RRL-QG-HSP			3	OVER	7 Y	4 Al
Milbank	200	U6396-O-200-10GR-HSP			1	UNDER	4 Y	3
Milbank	200	UAP9701-X-QG-HSP			3	OH/UG	7 Y	4 Al
Milbank	200	U588(y)-X-HSP (y= # of positions, 2,3,4,5,6)			1	Mtr Ctr	4/5 N	1
Milbank	200	U6549-XL-200NF Cold Sequence, check with utility for use			1	OH/UG	4/5 Y	3,3a
Milbank	200	U6615-XL-200NF Cold Sequence, check with utility for use			3	OH/UG	5 Y	3a
Milbank	200	U6550-XL-200NF Cold Sequence, check with utility for use			3	OH/UG	7 Y	4
Milbank	200	U6551-XL-200F Cold Sequence, check with utility for use			1	OH/UG	4/5 Y	3,3a
Milbank	200	U6616-XL-200F Cold Sequence, check with utility for use			3	OH/UG	5 Y	3a
Milbank	200	U6552-XL-200F Cold Sequence, check with utility for use			3	OH/UG	7 Y	4
Milbank	400	U1129-O-K3L-K2L-HSP			1	UNDER	4/5 Y	3,3a
Milbank	400	U2120-O-HSP			3	OH/UG	7 Y	4
Milbank	400	U2124-O-HSP			1	UNDER	4 Y	3
Milbank	400	U3313-X-HSP			1	OH/UG	5 Y	3,3a
Milbank	400	U3566-X-HSP			3	OH/UG	7 Y	4
Milbank	400	U3949-X-HSP			1	OVER	5 Y	3,3a
Milbank	400	U4363-X-HSP			1	OVER	4 Y	3
Milbank	400	U5864-X-HSP			1	OH/UG	5 Y	3,3a
Milbank	400	U5890-X-2/150-HSP			1	OH/UG	4 Y	3
Milbank	400	U5890-X-2/200-HSP			1	OH/UG	4 Y	3
Milbank	400	U5890-X-200-150-HSP			1	OH/UG	4 Y	3



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Milbank	400	U5891-X-2/150-MLK-HSP			1	OH/UG	4 Y	3
Milbank	400	U5891-X-2/200-MLK-HSP			1	OH/UG	4 Y	3
Milbank	400	U6115-X-2/200-K7L-HSP			3	OH/UG	7 Y	4
Milbank	400	U6227-X-400-K3L-HSP			1	OH/UG	4 Y	3
Milbank	400	U6229-X-400-K7L-HSP			3	OH/UG	7 Y	3a
Milbank	400	U6267-X-2/100-HSP			1	OH/UG	4 Y	3
Milbank	400	U6267-X-2/150-HSP			1	OH/UG	4 Y	3
Milbank	400	U6587-X-2/200-HSP**			1	OH/UG	4 Y	3
Milbank	400	U6267-X-2/200-HSP			1	OH/UG	4 Y	3
Milbank	400	U6267-X-200-150-HSP			1	OH/UG	4 Y	3
Milbank	400	U6272-X-HSP			1	OH/UG	4 Y	3
Milbank	400	UAP2124-O-HSP			1	UNDER	4 Y	4 Al
Milbank	400	UAP3313-X-HSP			1	OH/UG	5 Y	3,3a Al
Milbank	400	UAP3566-X-HSP			3	OH/UG	7 Y	4 Al
Milbank	400	UAP3949-X-HSP			1	OVER	5 Y	3,3a Al
Milbank	400	UAP5864-X-HSP			1	OH/UG	5 Y	3,3a Al
Milbank	400	UAP6272-X-HSP			1	OH/UG	4 Y	3 Al
Milbank	400	UAP6601-X-2/200-5T9-HSP (Aluminum)			1	OH/UG	4/5 Y	1,2,3,3a
Milbank	400	U6602-X-2/200-5T9-MLK-HSP			1	OH/UG	4/5 Y	1,2,3,3a
Milbank	400	UAP6602-X-2/200-5T9-MLK-HSP (Aluminum)			1	OH/UG	4/5 Y	1,2,3,3a
Milbank	400	U6601-X-2/200-5T9-HSP			1	OH/UG	4/5 Y	1,2,3,3a
Milbank	60	U6419-XL-HSP			1	OH/UG	4 N	1
Milbank	60	U6421-XL-HSP			1	OH/UG	4 Y	3
Milbank	600	U4667-X-8528 (Req. Ridged Lugs)		FPL ONLY	3	OH/UG	7 Y	5
Milbank	600	U4667-X-9526 (Req. Ridged Lugs)		FPL ONLY	3	OH/UG	7 Y	5
Milbank	600	UA4667-X-8529 (Req. Ridged Lugs)		FPL ONLY	3	OH/UG	7 Y	5 Al
Milbank	600	UA4667-X-9527 (Req. Ridged Lugs)		FPL ONLY	3	OH/UG	7 Y	5 Al
Pacific Technical	125	PTS93x14-### x=all options, ### =all options			1	OH	4 N	6
Pacific Technical	125	PTS93x24-### x=all options, ### =all options			1	UG	4 N	6
Pacific Technical	125	PTS93x34-### x=all options, ### =all options			1	OH/UG	4 N	6
Pacific Technical	125	PTS93x14-###-5J x=all options, ### =all options			1	OH	5 N	6
Pacific Technical	125	PTS93x24-###-5J x=all options, ### =all options			1	UG	5 N	6
Pacific Technical	125	PTS93x34-###-5J x=all options, ### =all options			1	OH/UG	5 N	6
Raycap	200	RMx-E2N-X12MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1
Raycap	200	RMx-E2N-Z12MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Raycap	200	RMx-E2C-X12MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1
Raycap	200	RMx-E2C-Z12MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1
Raycap	200	RMx-E2N-X02MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1
Raycap	200	RMx-E2N-Z02MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1
Raycap	200	RMx-E2C-X02MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1
Raycap	200	RMx-E2C-Z02MS-21NN (x= D(Gry), B(Blk), G(Grn),			1	OH/UG	4 N	1
Ronk	200	MSB200Lx4 (x=C, D, E, G)			1	OH	4/5 Y	1,2,3,3a
Ronk	200	MSB200Lx4-UG (x=C, D, E, G)			1	UG	4/5 Y	1,2,3,3a
Ronk	400	MSB320Lx4-UG (x=C, D, E, F)			1	UG	4/5 Y	1,2,3,3a
Siemens	100	MM0202B1100R			1	OH/UG	4 N	1
Siemens	125	SPxx11RJ (xx=22, 33, 44, 45, 46, 65, 66)			1	OH/UG	4/5 N	1,2
Siemens	125	SUAT111-OGF			1	OVER	4 N	1
Siemens	125	WMMx1125RJ (x=2-6)			1	OVER	5 N	1
Siemens	125	WMMx1125R (x=2-6)			1	UNDER	4/5 N	1,2
Siemens	125	WMMx2125RJ (x=2-6)			3	UNDER	5 N	2
Siemens	125	WPKxx11RJ (x=22,33,44,45,46,54,65,66) (NEC2020)			1	Mtr Ctr	4/5 N	2
Siemens	125	WP2211RJ			1	Mtr Ctr	5 N	2
Siemens	125	WP3311RJ			1	Mtr Ctr	5 N	2
Siemens	125	WP4X11RJ (x=4-6)			1	Mtr Ctr	5 N	2
Siemens	125	WP5411RJ			1	Mtr Ctr	5 N	2
Siemens	125	WP6x11RJ (x=5-6)			1	Mtr Ctr	5 N	2
Siemens	125	MM0202B1125R			1	OH/UG	4 N	1
Siemens	150	MM0202B1150R			1	OH/UG	4/5 N	1,2
Siemens	150	MC0408B1150RT			1	OH/UG	4 N	1
Siemens	150	MC0816B1150RCT			1	OH/UG	4 N	1
Siemens	150	MC0816B1150RTH			1	OH/UG	4/5 N	1,2
Siemens	150	MC2040B1150R			1	OH/UG	4/5 N	1,2
Siemens	150	MC2040B1150RC			1	OH/UG	4 N	1
Siemens	150	MC2040B1500R			1	OH/UG	4/5 N	1,2
Siemens	200	WPKxxxxRJ			1	Mtr Ctr	4/5 N	1,2
Siemens	200	MM0202B1200R			1	OH/UG	4/5 N	1,2
Siemens	200	MM0406L1200RH			1	OH/UG	4 N	1
Siemens	200	MC2020B1200R			1	OH/UG	4 N	1
Siemens	200	MC3042B1200RC			1	OH/UG	4 N	1
Siemens	200	MC3040B1200R			1	OH/UG	4 N	1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Siemens	200	MC4040B1200R			1	OH/UG	4 N	1
Siemens	200	MC0816B1200RTD			1	UNDER	4 N	1
Siemens	200	MM0202S1200RHJ			1	OH/UG	5 N	1,2
Siemens	200	MC0408B1200RT			1	OH/UG	4 N	1
Siemens	200	MC0606L1200R or RA			1	OH/UG	4/5 N	1, 1 Al
Siemens	200	MC0816B1200RCT			1	OH/UG	4 N	1
Siemens	200	MC0816B120RCT2			1	OH/UG	4 N	1
Siemens	200	MC0816B1200RTH			1	OH/UG	4/5 N	1,2
Siemens	200	MC2040B1200R			1	OH/UG	4/5 N	1,2
Siemens	200	MC2040B1200RC			1	OH/UG	4 N	1
Siemens	200	MC2040S1200JLC			1	OH/UG	4/5 Y	3
Siemens	200	S40405-015F			1	OH/UG	5 Y	3,3a
Siemens	200	S40407-015F			3	OH/UG	7 Y	4
Siemens	200	SPxx12RJ (xx=42, 43, 44, 65, 66)			1	OH/UG	4/5 N	1,2
Siemens	200	SUAT317-OGF			1	OVER	4 N	1
Siemens	200	SUAT417-PGF			1	UNDER	4/5 N	1,2
Siemens	200	SUAT417-XGF			1	OH/UG	4/5 N	1,2
Siemens	200	UAT417-XMF			1	OH/UG	5 N	2
Siemens	200	UAT417-XMF			1	OH/UG	5 N	2
Siemens	200	WMMx1225R (x=2-6)			1	UNDER	4/5 N	1,2
Siemens	200	WMMx2225RJ (x=2-6)			3	UNDER	5 N	2
Siemens	200	WP10612RJ			1	Mtr Ctr	4/5 N	1,2
Siemens	200	WP4x12RJ (x=2-4)			1	Mtr Ctr	4/5 N	1,2
Siemens	200	WP6x12RJ (x=4-6)			1	Mtr Ctr	4/5 N	1,2
Siemens	200	WP8612RJ			1	Mtr Ctr	4/5 N	1,2
Siemens	200	WPL10612RJ			1	Mtr Ctr	4/5 Y	3,3a
Siemens	200	WPL4x12RJ (x=2-4)			1	Mtr Ctr	4/5 Y	3,3a
Siemens	200	WPL6x12RJ (x=4-6)			1	Mtr Ctr	4/5 Y	3,3a
Siemens	200	WPL8612RJ			1	Mtr Ctr	4/5 Y	3,3a
Siemens	225	WML1x225RJ (x=1-4)			1	OH/UG	4/5 Y	3,3a
Siemens	225	WMLx1225RJ (x=2-6)			1	OH/UG	4/5 Y	3,3a
Siemens	225	WMLx2225RJ (x=1-4)			3	UNDER	7 Y	4
Siemens	225	WMLx2yz225RJ (x=2 or 4) (yz=AB, BC or CA)			3	OH/UG	5 Y	3,3A
Siemens	225	WMLx3225RJ (x=1-4)			3	UNDER	7 Y	4
Siemens	250	WC2040B1TxR (x=1-9)			1	UNDER	4 N	1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Siemens	250	WC2040B1TxRJ (x=1-9)			1	UNDER	5 N	2
Siemens	250	WC2040B2TxRJ (x=1-9)			1	UNDER	5 N	2
Siemens	250	WCL2040B1TxRJ (x=1-9)			1	UNDER	4/5 N	1,2
Siemens	250	WCL2040B2TxRJ (x=1-9)			1	UNDER	4/5 Y	3,3a
Siemens	250	WCL2442B3TxRJ (x=1-9)			3	UNDER	7 Y	4
Siemens	400	MC0408B1400RLTM			1	OH/UG	4/5 Y	3,3a
Siemens	400	MC0816B1350RLTM			1	OH/UG	4/5 Y	3,3a
Siemens	400	MC0816B1400RLTM			1	OH/UG	4/5 Y	3,3a
Siemens	400	MC3042B1400SDL			1	OH/UG	4 N	1
Siemens	400	MK0402L1400RLM (NEC2020)			1	OH/UG	4/5 Y	3,3a
Siemens	400	MM0404L1400RLM			1	OH/UG	4/5 Y	3,3a
Siemens	400	WML11400RJH			1	OH/UG	5 Y	3a
Siemens	400	WML12400RJH			3	OH/UG	5 Y	3a
Siemens	400	WML13400RJ			3	OH/UG	7 Y	4
Siemens	400	WML13400RJFS			3	OH/UG	7 Y	4
Siemens	400	WML13400RJH			3	OH/UG	7 Y	4
Siemens	400	WMLxy400RJ where (x=1-2) (y=1-2)			1	OH/UG	4/5 Y	3,3a
Siemens	400	WMLxy400RJFS where (x=1-2) (y=1-2)			1	OH/UG	4/5 Y	3,3a
Siemens	600	WMK13600RJ FPL Only			1,3	UNDER	7 Y	5
Square D	100	QU48F100PS			1	UNDER	4 N	1
Square D	100	RU48F100PS			1	UNDER	4 N	1
Square D	125	EZMR11y125 (y=3-6)			1	Mtr Ctr	5 N	1,2
Square D	125	EZMR11y125CU (y=3-6)			1	Mtr Ctr	5 N	1,2
Square D	125	EZMR11y125X (y=3-6)			1	Mtr Ctr	5 N	1,2
Square D	125	EZMR31y125 (y=3-6)			1	Mtr Ctr	5 N	1,2
Square D	125	EZMR31y125CU (y=3-6)			1	Mtr Ctr	5 N	1,2
Square D	125	EZMR31y125X (y=3-6)			1	Mtr Ctr	5 N	1,2
Square D	125	MPRyy125 (yy=22,33,44,55,66)			1	OH/UG	5 N	1,2
Square D	125	QC816F125C			1	OH/UG	4/5 N	1,2
Square D	125	RU48F125PS			1	UNDER	4 N	1
Square D	125	QU48F125PS			1	UNDER	4 N	1
Square D	150	QC816F150C			1	OH/UG	4/5 N	1,2
Square D	150	RU816F150PS			1	UNDER	4 N	1
Square D	150	RU48F150PS			1	UNDER	4 N	1
Square D	150	RC816F150C			1	OH/UG	4/5 N	1,2



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Square D	150	QU48F150PS			1	UNDER	4	N 1
Square D	150	QU816F150PS			1	UNDER	4	N 1
Square D	150	RQC150SFMG			1	OH/UG	4/5	N 1,2
Square D	200	EZML11y200 (y=1-4)			1	Mtr Ctr	5	Y 1,2
Square D	200	EZML31y200 (y=2-4)			1	Mtr Ctr	5	Y 3a
Square D	200	EZML33y200 (y=1-4)			3	Mtr Ctr	7	Y 4
Square D	200	EZMR11y200 (y=2-4)			1	Mtr Ctr	5	N 1,2
Square D	200	EZMR11y200CU (y=2-4)			1	Mtr Ctr	5	N 1,2
Square D	200	EZMR11y200X (y=2-4)			1	Mtr Ctr	5	N 1,2
Square D	225	MPLyy225 (yy=32,43,64)			1	OH/UG	5	Y 3
Square D	200	MPR4y200 (y=2-3)			1	OH/UG	5	N 1,2
Square D	200	MPR64200			1	OH/UG	5	N 1,2
Square D	200	MPR8y200 (y=5-6)			1	OH/UG	5	N 1,2
Square D	200	QC12L200C			1	OH/UG	4/5	N 1,2
Square D	200	QC2442M200C			1	OH/UG	4/5	Y/N 1,2
Square D	200	QC3040M200S			1	OH/UG	4/5	N 1,2
Square D	200	QC816F200C			1	OH/UG	4/5	N 1,2
Square D	200	RC12L200C			1	OH/UG	4/5	N 1,2
Square D	200	RC200SFMG			1	OH/UG	4/5	N 1,2
Square D	200	RC2040M200C			1	OH/UG	4/5	N 1,2
Square D	200	RC2M200SFMG			1	OH/UG	4/5	N 1,2
Square D	200	RC3042M200PS			1	OH/UG	4/5	N 1,2
Square D	200	RC816F200C			1	OH/UG	4/5	N 1,2
Square D	200	QU48F200PS			1	UNDER	4	N 1
Square D	200	QU816F200PS			1	UNDER	4	N 1
Square D	200	QU816M200PS			1	UNDER	4	N 1
Square D	200	RU48F200PS			1	UNDER	4	N 1
Square D	200	RU816F200PS			1	UNDER	4	N 1
Square D	200	RU816M200PS			1	UNDER	4	N 1
Square D	200	RQC200SFMG			1	OH/UG	4/5	N 1,2
Square D	200	UT-H5203x-FLSQD (x=B or T)			1	OVER	5	Y 3,3a,b
Square D	200	UT-H5213x-FLSQD (x=C or U)			1	OH/UG	5	Y 3,3a,b
Square D	200	UT-H7203x-FLSQD (x=B or T)			3	OVER	7	Y 4
Square D	200	UT-H7213x-FLSQD (x=C or U)			3	OH/UG	7	Y 4
Square D	200	UT-RS202B-FLSQD			1	OVER	4	N 1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating	Catalog Number (* - any number or letter)	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Square D	200	UT-RS212C-FLSQD			1	OH/UG	4 N	1
Square D	200	UT-RS213A-FLSQD			1	UNDER	4 N	1
Square D	200	UT-RS213C-FLSQD			1	OH/UG	4 N	1
Square D	200	UT-RS223A-FLSQD			1	UNDER	4 N	1
Square D	200	UT-xR2332U-FLSQD (x=2-3)			1	OH/UG	4 N	1
Square D	200	UT-xR2392UU-FLSQD (x=5-6)			1	OH/UG	4 N	1
Square D	225	EZML11x225 (x=1-4)			1	Mtr Ctr	5 Y	1,2
Square D	225	EZML31x225 (x=2-4)			1	Mtr Ctr	5 Y	3a
Square D	225	EZML33x225 (x=1-4)			3	Mtr Ctr	7 Y	4
Square D	225	EZMR11x200X (x=2-4)			1	Mtr Ctr	5 N	1,2
Square D	225	EZMR11x225 (x=2-6)			1	Mtr Ctr	5 N	1,2
Square D	225	EZMR11x225CU (x=2-6)			1	Mtr Ctr	5 N	1,2
Square D	225	EZMR31x225 (x=2-6)			1	Mtr Ctr	5 N	1,2
Square D	400	EZML31y400 (y=1-2)			1	Mtr Ctr	5 Y	3a
Square D	400	EZML33y400 (y=1-2)			3	Mtr Ctr	7 Y	4
Square D	400	QU12L400xL (x = C or S)			1	UNDER	4/5 Y	3
Square D	400	QU816D400SL			1	UNDER	4/5 Y	3
Square D	400	UT-H4300T-FLSQD			1	OVER	4 Y	1
Square D	400	UT-H5330U-FLSQD			1	OH/UG	5 Y	3,3a,b
Square D	400	UT-H7300T-FLSQD			3	OVER	7 Y	4
Square D	400	UT-H7336-8UFLSQD			3	OH/UG	7 Y	4
Square D	400	UT-H43068T-FLSQD			1	OH/UG	4 Y	1
Square D	400	UT-H7330U-FLSQD			3	OH/UG	7 Y	4
Talon	100	MP04061100R			1	UNDER	4 N	1
Talon	100	MP04061100R2			1	UNDER	4 N	1
Talon	100	MPS0406B1100R			1	UNDER	4 N	1
Talon	100	MPS0406B1100R2			1	UNDER	4 N	1
Talon	100	UAB111-XG			1	OH/UG	4 N	1
Talon	100	UAX411-XGF (X=2-6)			1	OH/UG	4 N	1
Talon	125	49205-025F			1	OVER	5 Y	3a
Talon	125	49207-025F			3	OVER	7 Y	4
Talon	125	49305-025F			1	OVER	5 Y	3a
Talon	125	49307-025F			3	OVER	7 Y	4
Talon	125	MP0406B1125R			1	UNDER	4 N	1
Talon	125	MP0406B1125R2			1	UNDER	4 N	1



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Talon	125	MPS0406B1125R			1	UNDER	4 N	1
Talon	125	MPS0406B1125R2			1	UNDER	4 N	1
Talon	125	TLxxRT (x=brkr/recpt config.)			1	OVER	4/5 N	1,2
Talon	125	TLxxxRC (x=brkr/recpt config.)			1	UNDER	4/5 N	1,2
Talon	125	TLxxxRM (x=brkr/recpt config.)			1	Un-Ped	4/5 N	1,2
Talon	125	TLxxxRP-F (x=brkr/recpt config.)			1	Un-Ped	4/5 N	1,2
Talon	125	WTG4x11RJ (X=4-6)			1	OH/UG	5 N	2
Talon	125	WTG5411RJ			1	OH/UG	5 N	2
Talon	125	WTG6x11RJ (X=5-6)			1	OH/UG	5 N	2
Talon	125	WTGxx11RJ (X=2-4)			1	OH/UG	5 N	2
Talon	135	UAT111-OGF			1	OH/UG	4 N	1
Talon	135	UAT111-XGF			1	OH/UG	4/5 N	1,2
Talon	135	UAT111-XMF			1	OH/UG	5 N	2
Talon	135	UAT131-XGF			1	OH/UG	4/5 N	1,2 Al
Talon	150	MP0406B1150R			1	UNDER	4 N	1
Talon	150	MP0406B1150R2			1	UNDER	4 N	1
Talon	150	MPS0406B1150R			1	UNDER	4 N	1
Talon	150	MPS0406B1150R2			1	UNDER	4 N	1
Talon	150	UAB417-150			1	OH/UG	4/5 N	1,2
Talon	200	40005-01F			1	OVER	5 Y	3,3a
Talon	200	40007-01F			3	OVER	7 Y	4
Talon	200	40404-025F			1	OH/UG	4 N	1
Talon	200	40405-015F			1	OH/UG	5 Y	3,3a
Talon	200	40405-025F			1	OH/UG	5 Y	3,3a
Talon	200	40405x-223F (x=2-6)			1	OH/UG	5 Y	3a
Talon	200	40407-015F			3	OH/UG	7 Y	4
Talon	200	40407-025F			3	OH/UG	7 Y	4
Talon	200	40407x-223F (x=2-6)			3	OH/UG	7 Y	4
Talon	200	41005-01F			1	OVER	5 Y	3,3a
Talon	200	41007-01F			3	OVER	7 Y	4 Al
Talon	200	41405-025F			1	OH/UG	5 Y	3,3a Al
Talon	200	41407-02GP			3	OH/UG	7 Y	4 Al
Talon	200	41407-02SE			3	OH/UG	7 Y	4 Al
Talon	200	41407-025F			3	OH/UG	7 Y	4 Al
Talon	200	46705-025F			1	OH/UG	5 Y	3a



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Talon	200	46707-025F			3	OH/UG	7 Y	4
Talon	200	46805-025F			1	OH/UG	5 Y	3a
Talon	200	46807-025F			3	OH/UG	7 Y	4
Talon	200	LG0408B1200RT			1	OH/UG	4 N	1
Talon	200	LG0606L1200R or RA			1	OH/UG	4/5 N	1,2 Al
Talon	200	LG0816B1200RCT			1	OH/UG	4 N	1
Talon	200	MP0406B1200R			1	UNDER	4 N	1
Talon	200	MP0406B1200R2			1	UNDER	4 N	1
Talon	200	MP0406L1200R			1	UNDER	4 N	1
Talon	200	MP0406L1200R2			1	UNDER	4 N	1
Talon	200	MPS0406B1200R			1	UNDER	4 N	1
Talon	200	MPS0406B1200R2			1	UNDER	4 N	1
Talon	200	UA27x6-ZGF (x=1 or 3)			1	OH/UG	4 N	1 Al
Talon	200	UA37x7-ZGF (x=1 or 3)			1	OH/UG	4 N	1 Al
Talon	200	UA47x9-ZGF (x=1 or 3)			1	OH/UG	4 N	1 Al
Talon	200	UA57x9-MGF (x=1 or 3)			1	OH/UG	4 N	1 Al
Talon	200	UA67x9-MGF (x=1 or 3)			1	OH/UG	4 N	1 Al
Talon	200	UAB417-200			1	OH/UG	4/5 N	1,2
Talon	200	UAB417-XPG			1	OH/UG	4 N	1
Talon	200	UAS877-PGF			1	UNDER	4 N	1
Talon	200	UAT317-OGF			1	OVER	4/5 N	1,2
Talon	200	UAT337-OGF			1	OVER	4/5 N	1,2 Al
Talon	200	UAT417-PGF			1	UNDER	4/5 N	1,2
Talon	200	UAT417-XGF			1	OH/UG	4/5 N	1,2
Talon	200	UAT417-XMF			1	OH/UG	5 N	1,2 Al
Talon	200	UAT437-PGF			1	UNDER	4/5 N	1,2 Al
Talon	200	UAT437-XGF			1	OH/UG	4/5 N	1,2 Al
Talon	200	UAT777-XGF			1	OH/UG	4 N	1
Talon	200	UAx711-ZGF (x=2-4)			1	OH/UG	4 N	1
Talon	200	UAx715-MGF (x=5-6)			1	OH/UG	4 N	1
Talon	200	UAx71y-ZGF (x=2-4) (y=4-5)			1	OH/UG	4 N	1
Talon	225	WTG10612RJ			1	OH/UG	5 N	2
Talon	225	WTG4x12RJ (X=2-4)			1	OH/UG	5 N	2
Talon	225	WTG6x12RJ (X=4-6)			1	OH/UG	5 N	2
Talon	225	WTG8612RJ			1	OH/UG	5 N	2



Electric Utility

APPROVED METERING EQUIPMENT ENCLOSURE LIST

(Revised: 11/01/2023)

Manufacturer	Amp Rating (* - any number or letter)	Catalog Number	Phase	Over/Under	# Pos	# Term	Bypass Y/N	Configuration (AL=Aluminium)
Talon	225	WTGL10612RJ			1	OH/UG	5 Y	3a
Talon	225	WTGL4x12RJ (x=2-4)			1	OH/UG	5 Y	3a
Talon	225	WTGL6x12RJ (x=4-6)			1	OH/UG	5 Y	3a
Talon	225	WTGL8612RJ			1	OH/UG	5 Y	3a
Talon	400	40905-02FL			1	OH/UG	5 Y	3a
Talon	400	41105-02FL			1	OH/UG	4/5 Y	3,3a AL
Talon	400	44707-02FL			3	OH/UG	7 Y	4
Talon	400	46905-02FL			1	OH/UG	5 Y	3a
Talon	400	47005-02FL			1	OH/UG	5 Y	3a
Talon	400	47205-02FL			1	OH/UG	5 Y	3a
Talon	400	47205-82FL			1	OH/UG	5 Y	3a
Talon	400	47305-02FL			1	OH/UG	5 Y	3a
Talon	400	47305-82FL			1	OH/UG	5 Y	3a
Talon	400	47407-02FL			3	UNDER	7 Y	4
Talon	400	47504-92			3	UNDER	4 Y	3
Talon	400	47604-82			3	OH/UG	4/5 Y	3,3a
Talon	400	47705-02FL			1	OH/UG	4/5 Y	3,3a
Talon	400	48504-92			1	UNDER	4 Y	3
Talon	400	49005-02FL			1	OH/UG	4/5 Y	3,3a
Talon	400	49007-02FL			3	OH/UG	7 Y	4
Talon	400	49105-02FL			1	OH/UG	4/5 Y	3,3a AL
Talon	400	49107-02FL			3	OH/UG	7 Y	4 AL
Talon	600	9817-9526 (Requires Ridged Lugs) FPL ONLY			1,3	OH/UG	7 Y	5
Talon	600	9817-9527 (Requires Ridged Lugs) FPL ONLY			1,3	OH/UG	7 Y	5 AL